

# VOC Content Test Certificate

Thursday December 31<sup>st</sup>, 2009

Manufacturer: Bostik New Zealand Limited (19 Eastern Hutt Road, Wingate Lower Hutt New Zealand 5019)

Sample Description: Bostik Safe Seal High Performance Construction Sealant

Date Tested: December 2009 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<b>Specification</b>	<b>Bostik Safe Seal High Performance Construction Sealant</b>
<b>New Zealand Green Building Council Green Star NZ Office 2009 IEQ-3 Green Star NZ Office Interiors IEQ-3</b>	<b>Bostik Safe Seal High Performance Construction Sealant</b>
Architectural Sealant 250 grams per Litre as VOC content material.	10 grams per Litre as VOC content material
<b>Specification</b>	<b>Bostik Safe Seal High Performance Construction Sealant</b>
<b>Green Building Council Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors IEQ-11</b>	<b>Bostik Safe Seal High Performance Construction Sealant</b>
Architectural Sealant 250 grams per Litre as VOC content material.	10 grams per Litre as VOC content material



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

F0911-35